



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - KOL 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500124827
Project #: SFIS #: 6104

31-May-2016

PWBS-Brant Haldimand Norfolk DCSB (Reg243) Notre Dame-Caledonia

Attn : Paul Viszy (PWBS)

Date Rec. : 25 May 2016
LR Report: CA19188-MAY16

535 Paris Rd..
 Paris, ON
 N3L 3E1,

Copy: #1

Phone: 519-753-3266
 Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	27-May-16
2: Analysis Start Time		---	13:21
3: Analysis Approval Date		---	27-May-16
4: Analysis Approval Time		---	13:35
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Rm 146	21-May-16 08:15	22.4	1.26
8: TAP Flushed - Rm 146	21-May-16 08:50	22.4	0.96

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code	Reference Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	SM 3030/EPA 200.8

Patti Stark
 Project Specialist Environmental Services,
 Analytical