



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500009049

Project : SFIS #: 4318

19-June-2017

PWBS-Brant Haldimand Norfolk DCSB (Reg243) St Michael Simcoe

Attn : Paul Viszy (PWBS)

Date Rec. : 06 June 2017

LR Report: CA19119-JUN17

174 Stanley St. Unit 300
Brantford, ON
N3S 7S3,

Copy: #1

Phone: 519-753-3266
Fax:519-753-7072

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature upon Delivery @ London Lab °C	Lead ug/L
1: Analysis Start Date		---	14-Jun-17
2: Analysis Start Time		---	13:30
3: Analysis Approval Date		---	14-Jun-17
4: Analysis Approval Time		---	16:15
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Cor 119 Drinking Spout	04-Jun-17 12:33	19.4	0.01 <MDL
8: TAP Flushed - Cor 119 Drinking Spout	04-Jun-17 13:08	19.4	0.01 <MDL
9: TAP Standing - Cor 103 Drinking Spout	04-Jun-17 12:33	19.4	0.01 <MDL
10: TAP Flushed - Cor 103 Drinking Spout	04-Jun-17 13:08	19.4	0.01 <MDL

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Patti Stark
*Project Specialist Environmental Services,
Analytical*